



CONSTRUCTION PRODUCTS REGULATION 2011 DECLARATION OF PERFORMANCE

DoP Number: IH-DCL-CAMCON-11205— Issue 1

1. Unique identification of the product type:

Controlled door closing Devices

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

IH-DCL-CAMCON-11205

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer

For use on fire and smoke compartmentation doors and escape route doors, when fitted in accordance with the manufacturers fitting instructions

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

UAP Limited, Orbital 60, Dumers Lane, Bury, Greater Manchester, Uni, BL9 9UE

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

SYSTEM 1

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard please give the Notified Body Number:

EN 1154: 1996: A1: 2002/AC:2006

Notified product certification body No: 2812 performed the type testing and issued test reports.

Certificate of Constancy of Performance: 2812-CPR-AD10510

8. European Technical Assessment:

N/A Fire Security Innovation





9. Declared Performance

9. Declared Performance Essential characteristic Self	Performance	Harmonised
closing	renormance	technical
Closing		specification
5.2.1 General		Specification
Application	Concealed in the Door	-
5.2.2 Durability	500,000 test cycles	-
	Pass size 2 - 5	-
5.2.3 Closing moment		-
5.2.4 Opening moment	Pass size 2 - 5	-
5.2.5 Efficiency;	More than 50% size 2	
	More than 55% size 3	
	More than 60% size 4	
	More than 65% size 5	-
5.2.6 Closing time	Pass- After 5K and 500K test cycles, the closing time from an	
	opening angle of 90° was	
	capable of adjustment to 3 s or less, and 20 s or more- After 500K test	
	cycles, the closing time set at 5K test cycles did not increase by more	
	than 100%, or decrease by more	
	than 30%.	-
5.2.7 Angles of operation	Grade 3, 105°	-
5.2.8 Overload performance	Pass - The closer withstood the closing	
	overload tests	-
5.2.9 Temperature	-15°C to +40°C	
dependence		
5.2.10 Fluid leakage	Pass - There was no leakage of fluid from the	
	closer	EN1154:1996:
5.2.11 Damage	Pass - There was no damage to the door closing device that would	A1:2002/AC:2006
	adversely affect its	
	performance to the standard	
5.2.12 Latch control	Pass - Effective over max. range of 15° from	
	closed position, and adjustable	
5.2.13 Backcheck	N/A	
5.2.14 Delayed closing	N/A	1
5.2.15 Adjustable closing force	Pass	-
		-
5.2.16 Zero position (Double	N/A	
action only)		-
5.2.18 Fire / smoke doors	Grade 1: Suitable for use on fire/smoke door	
	assemblies	-
5.2.2 Durability	Grade 8 500,000 test cycles	
5.2.17.1 Corrosion	Grade 3:96 hrs	
5.2.17.2 Corrosion	Pass - After the salt spray test, the closing	
	moment of the door closer was not less than 80% of	
	that measured prior to the test.	
Dangerous Substances Annex	The materials in the product do not contain or release any dangerous	
ZA3	substances in excess of the	
	maximum levels specified in existing European material standards or any	
	national regulations.	
	1	I

Fire Security Innovation





10. The performance of the product identified in points 1 and 2 as in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer at:

UAP Limited, Orbital 60, Dumers Lane, Bury, Greater Manchester, United Kingdom, BL9 9UE

Dated: 23rd May 2025

Fire Security Innovation